

Certificate

Indoor Air Comfort Gold



Acoustix Gallery fx, Acoustix Forest fx, Acoustix Harmony fx 43, Polyflor Secura
Product

Riverside Flooring Ltd., Fleck Way, Teesside, Thornaby on Tees TS17 9JT, UK
Manufacturer

The product has undergone a successful testing and evaluation program as specified for Eurofins Indoor Air Comfort Gold certification, version 3.1 (2011). This includes a VOC emission chamber test and an audit of the manufacturing site.


Successful evaluation means:

- ☒ No carcinogenic substances were detectable above their limit values, including 4 CMR substances regulated in France.
- ☒ Formaldehyde was below the limit value of 10 µg/m³.
- ☒ Sum of VOC (TVOC) was below the limit values of 1.000 µg/m³ after 3 days and 160 µg/m³ after 28 days. The product was classified A+ according to French VOC regulation.
- ☒ Sum of SVOC after 28 days was below the limit value of 30 µg/m³.
- ☒ Evaluation of individual VOC: R values were below the limit values of 1 for both German NIK and French LCI lists after 28 days. Sums of VOC without German NIK and French LCI both were below 100 µg/m³.
- ☒ Quality management system and factory production control program at production site complied with the requirements.
- ☒ Therefore the product qualifies for the Indoor Air Comfort Gold label.

Certificate No.: 2012 - IACG - 40

Date: 01-04-2012

Validity of certificate: 01-04-2017



Director Certification Chemical Safety



General Manager

Eurofins Product Testing A/S
Tel. +45 70 22 42 76

ProductTesting@eurofins.com
www.product-testing.eurofins.com

Sampling, testing and evaluation were performed according to the standards ISO 16000-3, ISO 16000-6, ISO 16000-9, ISO 16000-11, ISO 16017-1, EN 13419 in the latest versions.