

# Certificate

## Indoor Air Comfort Gold



***Polyflor homogeneous PVC flooring***  
Product

***Polyflor Limited, Radcliffe New Road, Whitefield Manchester M45 7NR, UK***  
Manufacturer

The product has undergone a successful testing and evaluation program as specified for Eurofins Indoor Air Comfort Gold certification, version 3.1 (2011). This includes a VOC emission chamber test and an audit of the manufacturing site.


### Successful evaluation means:

- ☒ No carcinogenic substances were detectable above their limit values, including 4 CMR substances regulated in France.
- ☒ Formaldehyde was below the limit value of 10  $\mu\text{g}/\text{m}^3$ .
- ☒ Sum of VOC (TVOC) was below the limit values of 1.000  $\mu\text{g}/\text{m}^3$  after 3 days and 160  $\mu\text{g}/\text{m}^3$  after 28 days. The product was classified A+ according to French VOC regulation.
- ☒ Sum of SVOC after 28 days was below the limit value of 30  $\mu\text{g}/\text{m}^3$ .
- ☒ Evaluation of individual VOC: R values were below the limit values of 1 for both German NIK and French LCI lists after 28 days. Sums of VOC without German NIK and French LCI both were below 100  $\mu\text{g}/\text{m}^3$ .
- ☒ Quality management system and factory production control program at production site complied with the requirements.
- ☒ Therefore the product qualifies for the Indoor Air Comfort Gold label.

Certificate No.: 2012 - IACG - 46

Date: 15-04-2012

Validity of certificate: 15-04-2017

  
Director Certification Chemical Safety

  
General Manager

Eurofins Product Testing A/S  
Tel. +45 70 22 42 76

ProductTesting@eurofins.com  
www.product-testing.eurofins.com

Sampling, testing and evaluation were performed according to the standards ISO 16000-3, ISO 16000-6, ISO 16000-9, ISO 16000-11, ISO 16017-1, EN 13419 in the latest versions.



The manufacturer / establishment

**Polyflor Limited**  
**Radcliffe New Road, Whitefield**  
**Manchester M45 7NR**  
**United Kingdom**

receives the Certificate Indoor Air Comfort - Gold  
with No. 2012-IACG-046 and validity 15/04/2017

for product group:

**Polyflor homogeneous PVC flooring**

including the individual products with same construction properties and VOC emission profile:

Polyflor Prestige PUR  
Polyflor Standard XL  
Polyflor XLPU  
Polysafe Ecomax  
Polyflor 2000 PUR  
Polyflor Mystique PUR  
Polyflor Classic Mystique PUR  
Polyflor Pearlazzo PUR  
Polyflor Smart PUR

Following certification, the manufacturer will be authorised to use the certification, the appendix to certification and the above certification mark for any business documents, brochures, catalogues, delivery notes, offers, advertisements etc. in fairs and in Internet in connection with the name of the manufacturer / establishment.

  
Director Certification Chemical Safety  
General Manager

**Eurofins Product Testing A/S**  
Tel. +45 70 22 42 76

ProductTesting@eurofins.com  
www.product-testing.eurofins.com

Sampling, testing and evaluation were performed according to the standards ISO 16000-3,  
ISO 16000-6, ISO 16000-9, ISO 16000-11, ISO 16017-1, EN 13419 in the latest versions.